

CITY OF SPRINGFIELD  
INTER-OFFICE MEMORANDUM

ENTENTION OF \_\_\_\_\_ FILE \_\_\_\_\_

DATE \_\_\_\_\_ 1-6-84 \_\_\_\_\_

DEPARTMENT \_\_\_\_\_

Re: INDIV

On Thursday, December 29, 1983, we received a complaint from INDIV, Inc., 217 S. Campbell, operated by Forest W. Lipscomb, Jr., in regard to a solvent odor throughout the building. The problem at first reminded us of earlier problems encountered in March of 1981. When we arrived at the scene, very strong odor was encountered throughout the building. No vapors or odors could be detected in the City sewer and 0% L.E.L. was measured. Further investigation revealed that painting and remodeling at T. J. Sales, 215 S. Campbell was being done. Gene Pabst and myself entered 215 S. Campbell and found freshly painted walls and paint thinner and brush cleaner had been used and a stronger odor in the basement than in 217 S. Campbell. We informed Patty, the Office Manager at INDIV, of that and told her this was probably the source of the problem. She was informed that if she wanted the Health Dept. to investigate to let us know. Also, we smoke-tested the sewer and found a large amount of smoke entering thru the ceiling of the S.E. office in the basement, as it had earlier in 1981. Patty was informed of the seriousness of such a situation and said she would pass it along to Mr. Lipscomb.

SIGNED \_\_\_\_\_ Randy Lyman  
Water Pollution Control Inspector, III  
Surveillance & Enforcement

217 S. CAMPBELL